



ARCHITECTS ENGINEERS SURVEYORS

23 North Walnut Street
Milford, DE 19963
PHONE (302) 424-1441
FAX (302) 424-0430

M E M O R A N D U M (via e-mail)

TO: Prospective Bidders
FROM: Ring W. Lardner, P.E. *(RWL)*
DATE: February 21, 2013
RE: DEARNG Contract No.: 09-2012
FMS #4 Wash Rack Replacement
Addendum 2
DBF# 999J009.002

The question period ended at 12:00 P.M. on February 21, 2013. We received two questions. On behalf of the owner, we offer the answers to the received questions and is further known as Addendum 2:

1. *The drawings call for various types of grating manufactured by McNichols. Can we use equal products from another manufacturer? **Yes, but they must be approved by the engineer. Contractor to provide supporting data via submittal.***
2. *This is a follow up to the question I sent last Friday.*
 - a. *Our grating supplier will quote us the two following material substitutions for the McNichols Grating noted on the plans:*
 - b. *Where McNichols GHB 1" x 1/4" is shown use Ohio Grating 19W4 1" x 1/4" Smooth surface, galvanized finished, banded ends.*
 - c. *Where McNichols GHB 3" x 1/4" is shown use Ohio Grating 19W4 3" x 1/4" Smooth surface, galvanized finished, banded ends.*

- d. *Additionally, the drawings call for hold down clips. However, there aren't any hold-down clips that will stand up to vehicular or heavy-duty loading. Therefore they are suggesting the use of a welded anchor block (4 per piece) in this application.*

*Please verify if these substitutions are acceptable. **Approved as noted.***

Contractors, upon receipt of this addendum, shall complete the attached Addendum Acknowledgement Statement form and return to Ring Lardner at DBF.

ADDENDUM ACKNOWLEDGEMENT STATEMENT

Our company, _____, hereby acknowledges that we have received and read Addendum 2 for DEARNG Contract No. 09-2012.

Signature

Printed Name

Date

Note: This form must be signed and returned to Davis, Bowen, & Friedel, Inc. by facsimile (302) 424-0430 or e-mail at rwl@dbfinc.com.